

March 28, 2023

Via Email: village.leask@sasktel.net

Village of Leask
Box 40
Leask SK, S0J 1M0


Dear Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for the Village of Leask - Rescinded

The Water Security Agency (WSA) is satisfied with the new pump installation, negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following the new pump installation and possibility of contamination in the treated water reservoir. Therefore, effective immediately the WSA is rescinding the “**Precautionary Drinking Water Advisory**” for the residents and users of the Village of Leask’s water supply.

For further information please do not hesitate to contact the undersigned at (306) 961-8400 or evan.mcleod@wsask.ca

Sincerely,



WATER SECURITY AGENCY

Evan McLeod

Environment Officer

cc: Ries Mansuy, Water Security Agency
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Prince Albert